



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Official Laboratory Report

Report To: CITY OF STEPHENSON
PO BOX 467
STEPHENSON MI 49887

Sample ID: LL79647
Work Order: 50800645_01

System Name/Owner: CITY OF STEPHENSON
Collection Address: N201 SECTION ST, STEPHENSON
Collected By: JORDAN BELEC
Township/Well#/Section: STEPHENSON/2/
County: Menominee
Sample Point: PLANT TAP
Water System: Pressure Tank/Plant Tap

WSSN/Pool ID: 6380
Source: TYPE I
Site Code: TP001
Collector: Other
Date Collected: 08/05/2025 00:45
Date Received: 08/06/2025 11:58
Purpose: Routine Monitoring

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

11CI-PF3OUdS	Not Detected	ng/L	2	08/08/2025		EPA 533	763051-92-9
4:2FTS	Not Detected	ng/L	2	08/08/2025		EPA 533	757124-72-4
6:2FTS	Not Detected	ng/L	2	08/08/2025		EPA 533	27619-97-2
8:2FTS	Not Detected	ng/L	2	08/08/2025		EPA 533	39108-34-4
9CI-PF3ONS	Not Detected	ng/L	2	08/08/2025		EPA 533	756426-58-1
ADONA	Not Detected	ng/L	2	08/08/2025		EPA 533	919005-14-4
HFPO-DA	Not Detected	ng/L	2	08/08/2025	370	EPA 533	13252-13-6
NFDHA	Not Detected	ng/L	2	08/08/2025		EPA 533	151772-58-6
PFBA	Not Detected	ng/L	2	08/08/2025		EPA 533	375-22-4
PFBS	Not Detected	ng/L	2	08/08/2025	420	EPA 533	375-73-5
PFDA	Not Detected	ng/L	2	08/08/2025		EPA 533	335-76-2
PFDoA	Not Detected	ng/L	2	08/08/2025		EPA 533	307-55-1
PFEESA	Not Detected	ng/L	2	08/08/2025		EPA 533	113507-82-7
PFHpA	Not Detected	ng/L	2	08/08/2025		EPA 533	375-85-9
PFHpS	Not Detected	ng/L	2	08/08/2025		EPA 533	375-92-8
PFHxA	Not Detected	ng/L	2	08/08/2025	400000	EPA 533	307-24-4
PFHxS	Not Detected	ng/L	2	08/08/2025	51	EPA 533	355-46-4
PFMBA	Not Detected	ng/L	2	08/08/2025		EPA 533	863090-89-5
PFMPA	Not Detected	ng/L	2	08/08/2025		EPA 533	377-73-1
PFNA	Not Detected	ng/L	2	08/08/2025	6	EPA 533	375-95-1
PFOA	Not Detected	ng/L	2	08/08/2025	8	EPA 533	335-67-1
PFOS	Not Detected	ng/L	2	08/08/2025	16	EPA 533	1763-23-1
PFPeA	Not Detected	ng/L	2	08/08/2025		EPA 533	2706-90-3
PFPeS	Not Detected	ng/L	2	08/08/2025		EPA 533	2706-91-4

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane



MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

MICHIGAN DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DRINKING WATER LABORATORY
USEPA Region V Drinking Water Cert. No. MI00003

P.O. Box 30270
Lansing, MI 48909
TEL: (517) 335-8184
FAX: (517) 335-8562

Sample ID: LL79647

Work Order: 50800645_01

TESTING INFORMATION					REGULATORY INFORMATION		
Analyte Name	Result	Units	RL	Date Tested	MCL/AL	Method	CAS #

Per-And Polyfluorinated Alkyl Substances

PFUnA	Not Detected	ng/L	2	08/08/2025		EPA 533	2058-94-8
-------	--------------	------	---	------------	--	---------	-----------

The analyses performed by the EGLE Drinking Water Laboratory were conducted using methods approved by the U.S. Environmental Protection Agency in accordance with the Safe Drinking Water Act, 40 CFR parts 141-143, and other regulatory agencies as appropriate.

Your local health department has detailed information about the quality of drinking water in your area. If you have concerns about the health risks related to the test results of your sample, please contact the Environmental Health Section through the address and telephone number listed below.

Public Health Delta & Menominee Counties
909 Tenth Ave.
Menominee, MI 49858
906 863-4451

RL: Reporting Limit

MCL: Maximum Contaminant Level

AL: Action Level

Not Detected: Not detected at or above the reporting limit (RL)

mg/L: milligrams / Liter (ppm)

ng/L: nanograms / Liter (ppt)

MPN: Most Probable Number

CFU: Colony Forming Unit

CAS: Chemical Abstract Service

Laboratory Contact: Marlene Kane